

PART 1 - GENERAL

1.1 Single phase to quasi 3-phase harmonic filter for 3-phase PWM AC Variable Frequency Drives being supplied with single phase voltage.

- .1 The harmonic mitigation equipment and all of its components shall be manufactured and tested in accordance with the latest applicable standards of UL, CSA and NEMA.
- .2 Demonstration of compatibility between the harmonic mitigation equipment and the VFD must be available upon request.
- .3 Harmonic mitigation equipment shall be warranted to be free of defects in materials and workmanship for a period of 12 months from the date of start-up or 18 months from the date of shipment.
- .4 Factory Performance Testing: Manufacturer must be capable of factory testing for harmonic mitigating performance and energy efficiency under actual variable frequency drive loads. A detailed description of the program and a sample test report must be provided at time of quotation.
- .5 Subject to compliance with all of the contract documents and specifications, the acceptable product and manufacturer is: LINEATOR-1Q3™ SUHF, by MIRUS International Inc. (905) 565-6900, Toll Free: (888) 866-4787

PART 2 - PRODUCT

2.1 Key Requirements:

- .1 The harmonic mitigation equipment shall treat all of the characteristic low frequency harmonics generated by a 3-phase, diode bridge rectifier load when supplied with single phase voltage (3rd, 5th, 7th, 9th, 11th, 13th, etc.). Total Harmonic Current Distortion shall be reduced by more than 10x when compared to a VFD without harmonic treatment and shall be less than 12% when measured at the input terminals of the harmonic mitigation equipment under full load operation.
- .2 The characteristic harmonics shall be suppressed without the need for individual tuning or the requirement to phase shift against other harmonic sources.
- .3 Harmonic mitigation shall be by passive inductor/capacitor network. Active electronic components shall not be used.
- .4 Power factor shall be .98 lagging to .95 leading in operating range from full to half load.
- .5 To ensure compatibility with engine generators, the harmonic mitigation equipment must never introduce a capacitive reactive power (KVAR), which is greater than 20% of its kVA rating.
- .6 The harmonic mitigation equipment shall not resonate with system impedances or attract harmonic currents from other harmonic sources.
- .7 The full load efficiency of the harmonic mitigation equipment / VFD combination shall be greater than 96%. The harmonic mitigation equipment itself shall have efficiency no less than 99%.

2.2 Basic Requirements:

- .1 All wiring shall be copper.
- .2 Insulation class: 220°C system. Temperature rise: 130°C
- .3 Anti-vibration pads shall be used between the reactor or transformer core and the enclosure.
- .4 Ventilated, sprinkler proof NEMA-3R enclosure.

2.3 Other Requirements:

- .1 [OPTION] Submit for approval before shipment certified production test results with serial numbers for harmonic mitigation performance and energy efficiency under actual variable frequency drive loading.

PART 3 - EXECUTION

3.1 Installation

- .1 The harmonic mitigation equipment shall be handled, stored and installed in accordance with the manufacturer's recommended installation practices as found in the installation, operation, and maintenance manual. Installation shall comply with all applicable codes.

3.2 Acceptance

- .1 [OPTION] Harmonic compliance shall be verified with onsite field measurements of both the voltage and current harmonic distortion at the input terminals of the harmonic mitigating equipment with and without the equipment operating. A recording type Fluke 41 or equivalent harmonics analyzer displaying individual and total harmonic currents and voltages must be utilized.



SCIGATE AUTOMATION (S) PTE LTD

No. 1 Bukit Batok Street 22 #01-01 Singapore 659592

Tel: (65) 6561 0488

Fax: (65) 6562 0588

Email: sales@scigate.com.sg

Web: www.scigate.com.sg

Business Hours: Monday - Friday 8.30am - 6.15pm